

**ADDITIONAL DATA TO BE GIVEN ALONG WITH EXAMINATION QUESTION
PAPER CIE4020**

SECTION A - SOIL MECHANICS

TERMINOLOGY, SYMBOLS AND UNITS

<u>Term</u>	<u>Symbol</u>	<u>Units</u>
Volume	V	m ³
Litre	l	Litre (= 1 x 10 ⁻³ m ³)
Mass	M	kg
Gravity	g	9.81 m/sec ²
Weight		kN = (kg x 9.81)/1000
Total volume	V	m ³
Volume of air	V _A	m ³
Volume of water	V _W	m ³
Volume of voids	V _V	m ³
Volume of solids	V _S	m ³
Mass of water	M _W	kg
Mass of solids	M _S	kg
Weight of water	W _W	kN
Weight of solids	W _S	kN
Total weight	W	kN
Specific gravity	G _s	None
Density of water	ρ _W	1000 kg/m ³
Unit weight of water	γ _w	9.81 kN/m ³
Void ratio	e	None
Degree of saturation	S _r	None
Moisture content	w	None
Porosity	n	None
Air void content	A _v	None
Bulk density	ρ _b	kg/m ³
Dry density	ρ _d	kg/m ³
Saturated density	ρ _{sat}	kg/m ³
Bulk unit weight	γ _b	kN/m ³
Dry unit weight	γ _d	kN/m ³
Saturated unit weight	γ _{sat}	kN/m ³

Please turn the page

FORMULAE

Density kg/m³

$$1. \rho_b = \frac{\rho_w (G+es)}{1+e}$$

$$2. \rho_b = \frac{\rho_w G(1+w)}{1+e}$$

$$3. \rho_d = \frac{\rho_w G}{1+e}$$

$$4. \rho_{sat} = \frac{\rho_w (G+e)}{1+e}$$

$$5. w G = e S$$

Transposing the above expressions:

From 3 above

$$6. e = \frac{\rho_w G}{\rho_d} - 1$$

$$7. \rho_{d \max} = \frac{\rho_w G(1-A_v)}{1+wG}$$

Unit weight kN/m³

$$\gamma_b = \frac{\gamma_w (G+es)}{1+e}$$

$$\gamma_b = \frac{\gamma_w G(1+w)}{1+e}$$

$$\gamma_d = \frac{\gamma_w G}{1+e}$$

$$\gamma_{sat} = \frac{\gamma_w (G+e)}{1+e}$$

From 3 above

$$e = \frac{\gamma_w G}{\gamma_d} - 1$$

$$\gamma_{d \max} = \frac{\gamma_w G(1-A_v)}{1+wG}$$

Please turn the page

DEFINITIONS

Density of water, ρ_w	$\frac{\text{mass of water}}{\text{volume of water}}$	$\frac{M_w}{V_w}$
Unit weight of water, γ_w	$\frac{\text{weight of water}}{\text{volume of water}}$	$\frac{W_w}{V_w}$
Specific gravity, G_s	$\frac{\text{density of solids}}{\text{density of water}}$	$\frac{\rho_s}{\rho_w}$
Moisture content, w	$\frac{\text{mass of water}}{\text{mass of solids}}$	$\frac{M_w}{M_s}$
Void ratio, e	$\frac{\text{volume of voids}}{\text{volume of solids}}$	$\frac{V_v}{V_s}$
Degree of saturation, S_r	$\frac{\text{volume of water}}{\text{volume of voids}}$	$\frac{V_w}{V_v}$
Porosity, n	$\frac{\text{volume of voids}}{\text{total volume}}$	$\frac{V_v}{V}$
Bulk density, ρ_b	$\frac{\text{total mass}}{\text{total volume}}$	$\frac{M}{V}$
Dry density, ρ_d	$\frac{\text{mass of solids}}{\text{total volume}}$	$\frac{M_s}{V}$
Saturated density, ρ_{sat}	$\frac{\text{total saturated mass}}{\text{total volume}}$	$\frac{M}{V}$
Bulk unit weight, γ_b	$\frac{\text{total weight}}{\text{total volume}}$	$\frac{W}{V}$
Dry unit weight, γ_d	$\frac{\text{weight of solids}}{\text{total volume}}$	$\frac{W_s}{V}$

PLEASE TURN THE PAGE FOR HYDRAULICS DATA

SECTION B – HYDRAULICS

. Recommended Roughness values

Classification (assumed clean and new unless otherwise stated)	Suitable values of k_s (mm)		
	Good	Normal	Poor
Smooth materials			
Drawn non-ferrous pipes of aluminium, brass, Copper, lead etc, and non-metallic pipes of Alkathene, glass, Perspex etc	-	0.003	-
Asbestos-cement	0.015	0.03	-
Metal			
Spun bitumen or concrete lined	-	0.03	-
Wrought iron	0.03	0.06	0.15
Rusty wrought iron	0.15	0.6	3.0
Uncoated Steel	0.015	0.03	0.06
Coated steel	0.03	0.06	0.15
Galvanised iron, coated cast iron	0.06	0.15	0.3
Uncoated cast iron	0.15	0.3	0.6
Tate relined pipes	0.15	0.3	0.6
Old tuberculated water mains with the following degrees of attack:			
Slight	0.6	1.5	3.0
Moderate	1.5	3.0	6.0
Appreciable	6.0	15	30
Severe	15	30	60
(Good: Up to 20 years use; Normal: 40 to 50 Years use, Poor: 80 to 100 years use)			
Wood			
Wood stave pipes, planed plank conduits	0.3	0.6	1.5
Concrete			
Precast concrete pipes with 'O' ring joints	0.06	0.15	0.6
Spun precast concrete pipes with 'O' ring joints	0.06	0.15	0.3
Monolithic construction against steel forms	0.3	0.6	1.5
Monolithic construction against rough forms	0.6	1.5	-
Clayware			
Glazed or unglazed pipe:			
With sleeve joints	0.03	0.06	0.15
With spigot and socket joints and 'O' ring seals - dia < 150 mm	-	0.03	-
With spigot and socket joints and 'O' ring seals - dia > 150 mm	0.003	0.03	-

Please turn the page

14

continued

 $k_s = 0.030 \text{ mm}$
 $i = 0.004 \text{ to } 0.1$

 ie hydraulic gradient =
 1 in 250 to 1 in 10

 Water (or sewage) at 15°C
 full bore conditions.

 velocities in m/s
 discharges in m^3/s

Gradient	Pipe diameters in mm :											
	350	375	400	450	500	525	600	675	700	750	800	825
0.00400 1/ 250	1.372 0.132	1.434 0.158	1.494 0.188	1.611 0.256	1.722 0.338	1.776 0.384	1.931 0.546	2.079 0.744	2.127 0.819	2.220 0.981	2.311 1.162	2.356 1.259
0.00420 1/ 238	1.409 0.136	1.472 0.163	1.534 0.193	1.653 0.263	1.767 0.347	1.822 0.394	1.982 0.560	2.133 0.763	2.182 0.840	2.278 1.007	2.372 1.192	2.417 1.292
0.00440 1/ 227	1.444 0.139	1.509 0.167	1.572 0.198	1.694 0.269	1.811 0.356	1.868 0.404	2.031 0.574	2.187 0.782	2.237 0.861	2.335 1.032	2.431 1.222	2.477 1.324
0.00460 1/ 217	1.479 0.142	1.545 0.171	1.610 0.202	1.735 0.276	1.854 0.364	1.912 0.414	2.080 0.588	2.239 0.801	2.290 0.881	2.390 1.056	2.488 1.251	2.536 1.356
0.00480 1/ 208	1.513 0.146	1.581 0.175	1.647 0.207	1.775 0.282	1.897 0.372	1.956 0.423	2.127 0.601	2.289 0.819	2.342 0.901	2.445 1.080	2.545 1.279	2.594 1.386
0.00500 1/ 200	1.546 0.149	1.616 0.178	1.683 0.212	1.814 0.288	1.938 0.381	1.999 0.433	2.173 0.615	2.339 0.837	2.393 0.921	2.498 1.103	2.600 1.307	2.650 1.416
0.00550 1/ 182	1.627 0.157	1.700 0.188	1.771 0.223	1.908 0.303	2.039 0.400	2.102 0.455	2.286 0.646	2.460 0.880	2.516 0.968	2.626 1.160	2.733 1.374	2.786 1.489
0.00600 1/ 167	1.704 0.164	1.780 0.197	1.855 0.233	1.998 0.318	2.135 0.419	2.201 0.477	2.393 0.677	2.575 0.922	2.634 1.014	2.749 1.215	2.861 1.438	2.916 1.559
0.00650 1/ 154	1.778 0.171	1.858 0.205	1.935 0.243	2.085 0.332	2.227 0.437	2.296 0.497	2.496 0.706	2.686 0.961	2.747 1.057	2.867 1.267	2.984 1.500	3.041 1.626
0.00700 1/ 143	1.850 0.178	1.933 0.213	2.013 0.253	2.168 0.345	2.316 0.455	2.388 0.517	2.596 0.734	2.793 0.999	2.856 1.099	2.981 1.317	3.102 1.559	3.162 1.690
0.00750 1/ 133	1.919 0.185	2.005 0.221	2.088 0.262	2.249 0.358	2.402 0.472	2.477 0.536	2.692 0.761	2.896 1.036	2.962 1.140	3.091 1.365	3.216 1.617	3.278 1.752
0.00800 1/ 125	1.986 0.191	2.074 0.229	2.161 0.272	2.327 0.370	2.485 0.488	2.562 0.555	2.785 0.787	2.996 1.072	3.064 1.179	3.197 1.412	3.327 1.672	3.390 1.812
0.00850 1/ 118	2.051 0.197	2.142 0.237	2.231 0.280	2.402 0.382	2.566 0.504	2.645 0.573	2.875 0.813	3.092 1.107	3.163 1.217	3.300 1.458	3.434 1.726	3.499 1.871
0.00900 1/ 111	2.114 0.203	2.208 0.244	2.300 0.289	2.476 0.394	2.645 0.519	2.726 0.590	2.962 0.838	3.186 1.140	3.259 1.254	3.400 1.502	3.538 1.778	3.605 1.927
0.00950 1/ 105	2.175 0.209	2.272 0.251	2.366 0.297	2.548 0.405	2.721 0.534	2.805 0.607	3.047 0.862	3.278 1.173	3.352 1.290	3.498 1.545	3.639 1.829	3.709 1.983
0.01000 1/ 100	2.235 0.215	2.334 0.258	2.431 0.306	2.617 0.416	2.795 0.549	2.882 0.624	3.131 0.885	3.367 1.205	3.443 1.325	3.593 1.587	3.738 1.879	3.809 2.036
0.01100 1/ 91	2.351 0.226	2.455 0.271	2.556 0.321	2.752 0.438	2.939 0.577	3.029 0.656	3.291 0.930	3.539 1.266	3.619 1.393	3.776 1.668	3.928 1.975	4.003 2.140
0.01200 1/ 83	2.461 0.237	2.570 0.284	2.676 0.336	2.881 0.458	3.076 0.604	3.171 0.686	3.444 0.974	3.703 1.325	3.787 1.458	3.951 1.746	4.111 2.066	4.189 2.239
0.01300 1/ 77	2.567 0.247	2.681 0.296	2.792 0.351	3.005 0.478	3.208 0.630	3.307 0.716	3.591 1.015	3.861 1.382	3.949 1.520	4.119 1.820	4.285 2.154	4.367 2.334
0.01400 1/ 71	2.670 0.257	2.788 0.308	2.903 0.365	3.124 0.497	3.335 0.655	3.437 0.744	3.733 1.055	4.013 1.436	4.104 1.579	4.281 1.891	4.454 2.239	4.538 2.426
0.01500 1/ 67	2.768 0.266	2.891 0.319	3.010 0.378	3.239 0.515	3.458 0.679	3.564 0.771	3.870 1.094	4.160 1.489	4.254 1.637	4.438 1.961	4.616 2.320	4.704 2.514
0.01600 1/ 62	2.864 0.276	2.990 0.330	3.113 0.391	3.350 0.533	3.576 0.702	3.686 0.798	4.002 1.132	4.302 1.540	4.399 1.693	4.589 2.027	4.773 2.399	4.864 2.600
0.01700 1/ 59	2.957 0.284	3.087 0.341	3.214 0.404	3.458 0.550	3.691 0.725	3.804 0.824	4.131 1.168	4.440 1.589	4.540 1.747	4.736 2.092	4.926 2.476	5.019 2.683
0.01800 1/ 56	3.047 0.293	3.181 0.351	3.312 0.416	3.563 0.567	3.803 0.747	3.919 0.848	4.255 1.203	4.574 1.637	4.677 1.800	4.878 2.155	5.074 2.550	5.170 2.764
0.01900 1/ 53	3.135 0.302	3.273 0.361	3.407 0.428	3.665 0.583	3.912 0.768	4.032 0.873	4.377 1.237	4.704 1.683	4.810 1.851	5.017 2.216	5.218 2.623	5.317 2.842
Coefficient for part-full pipes:												
	250	250	300	350	350	400	450	500	500	550	600	600

 $k_s = 0.030 \text{ mm}$ $i < 0.1$

Please turn the page

$k_s = 1.500\text{mm}$
 $i = 0.00015 \text{ to } 0.004$
 ie hydraulic gradient =
 1 in 6667 to 1 in 250

Water (or sewage) at 15°C
 full bore conditions.
 velocities in m/s
 discharges in m^3/s

19
 continued

Gradient	Pipe diameters in mm:											
	350	375	400	450	500	525	600	675	700	750	800	825
0.00075 1/ 1333	0.416 0.040	0.435 0.048	0.454 0.057	0.490 0.078	0.524 0.103	0.541 0.117	0.590 0.167	0.636 0.228	0.651 0.251	0.681 0.301	0.709 0.356	0.723 0.387
0.00080 1/ 1250	0.429 0.041	0.449 0.050	0.469 0.059	0.506 0.080	0.542 0.106	0.559 0.121	0.609 0.172	0.657 0.235	0.673 0.259	0.703 0.311	0.733 0.368	0.747 0.399
0.00085 1/ 1176	0.443 0.043	0.463 0.051	0.483 0.061	0.522 0.083	0.559 0.110	0.577 0.125	0.628 0.178	0.678 0.242	0.694 0.267	0.725 0.320	0.755 0.380	0.770 0.412
0.00090 1/ 1111	0.456 0.044	0.477 0.053	0.497 0.063	0.537 0.085	0.575 0.113	0.593 0.128	0.647 0.183	0.697 0.250	0.714 0.275	0.746 0.330	0.777 0.391	0.793 0.424
0.00095 1/ 1053	0.468 0.045	0.490 0.054	0.511 0.064	0.552 0.088	0.591 0.116	0.610 0.132	0.665 0.188	0.717 0.256	0.734 0.282	0.767 0.339	0.799 0.402	0.815 0.435
0.00100 1/ 1000	0.481 0.046	0.503 0.056	0.525 0.066	0.566 0.090	0.606 0.119	0.626 0.135	0.682 0.193	0.735 0.263	0.753 0.290	0.787 0.348	0.820 0.412	0.836 0.447
0.00110 1/ 909	0.504 0.049	0.528 0.058	0.550 0.069	0.594 0.095	0.636 0.125	0.657 0.142	0.716 0.202	0.772 0.276	0.790 0.304	0.825 0.365	0.860 0.432	0.877 0.469
0.00120 1/ 833	0.527 0.051	0.552 0.061	0.575 0.072	0.621 0.099	0.665 0.131	0.686 0.149	0.748 0.211	0.806 0.289	0.825 0.318	0.862 0.381	0.898 0.452	0.916 0.490
0.00130 1/ 769	0.549 0.053	0.574 0.063	0.599 0.075	0.647 0.103	0.692 0.136	0.714 0.155	0.778 0.220	0.839 0.300	0.859 0.331	0.898 0.397	0.935 0.470	0.954 0.510
0.00140 1/ 714	0.570 0.055	0.596 0.066	0.622 0.078	0.671 0.107	0.719 0.141	0.742 0.161	0.808 0.228	0.871 0.312	0.892 0.343	0.932 0.412	0.971 0.488	0.990 0.529
0.00150 1/ 667	0.590 0.057	0.617 0.068	0.644 0.081	0.695 0.111	0.744 0.146	0.768 0.166	0.837 0.237	0.902 0.323	0.923 0.355	0.965 0.426	1.005 0.505	1.025 0.548
0.00160 1/ 625	0.610 0.059	0.638 0.070	0.665 0.084	0.718 0.114	0.769 0.151	0.793 0.172	0.864 0.244	0.932 0.333	0.954 0.367	0.997 0.440	1.038 0.522	1.059 0.566
0.00170 1/ 588	0.629 0.060	0.658 0.073	0.686 0.086	0.740 0.118	0.792 0.156	0.818 0.177	0.891 0.252	0.961 0.344	0.983 0.378	1.027 0.454	1.071 0.538	1.092 0.584
0.00180 1/ 556	0.647 0.062	0.677 0.075	0.706 0.089	0.762 0.121	0.816 0.160	0.842 0.182	0.917 0.259	0.989 0.354	1.012 0.389	1.057 0.467	1.102 0.554	1.123 0.601
0.00190 1/ 526	0.665 0.064	0.695 0.077	0.725 0.091	0.783 0.125	0.838 0.165	0.865 0.187	0.942 0.266	1.016 0.364	1.040 0.400	1.087 0.480	1.132 0.569	1.154 0.617
0.00200 1/ 500	0.682 0.066	0.714 0.079	0.744 0.094	0.803 0.128	0.860 0.169	0.887 0.192	0.967 0.273	1.043 0.373	1.067 0.411	1.115 0.493	1.162 0.584	1.185 0.633
0.00220 1/ 455	0.716 0.069	0.749 0.083	0.781 0.098	0.843 0.134	0.902 0.177	0.931 0.202	1.014 0.287	1.094 0.391	1.119 0.431	1.170 0.517	1.219 0.613	1.243 0.664
0.00240 1/ 417	0.748 0.072	0.782 0.086	0.816 0.103	0.881 0.140	0.943 0.185	0.973 0.211	1.060 0.300	1.143 0.409	1.169 0.450	1.222 0.540	1.273 0.640	1.298 0.694
0.00260 1/ 385	0.779 0.075	0.815 0.090	0.849 0.107	0.917 0.146	0.981 0.193	1.013 0.219	1.103 0.312	1.190 0.426	1.217 0.469	1.272 0.562	1.325 0.666	1.351 0.722
0.00280 1/ 357	0.808 0.078	0.845 0.093	0.882 0.111	0.952 0.151	1.019 0.200	1.051 0.228	1.145 0.324	1.235 0.442	1.264 0.486	1.320 0.583	1.376 0.691	1.403 0.750
0.00300 1/ 333	0.837 0.081	0.875 0.097	0.913 0.115	0.985 0.157	1.055 0.207	1.088 0.236	1.186 0.335	1.278 0.457	1.308 0.503	1.367 0.604	1.424 0.716	1.452 0.776
0.00320 1/ 313	0.865 0.083	0.904 0.100	0.943 0.118	1.018 0.162	1.089 0.214	1.124 0.243	1.225 0.346	1.320 0.472	1.351 0.520	1.412 0.624	1.471 0.739	1.500 0.802
0.00340 1/ 294	0.891 0.086	0.932 0.103	0.972 0.122	1.049 0.167	1.123 0.221	1.159 0.251	1.262 0.357	1.361 0.487	1.393 0.536	1.456 0.643	1.516 0.762	1.546 0.827
0.00360 1/ 278	0.917 0.088	0.959 0.106	1.001 0.126	1.080 0.172	1.156 0.227	1.193 0.258	1.299 0.367	1.401 0.501	1.434 0.552	1.498 0.662	1.561 0.784	1.591 0.851
0.00380 1/ 263	0.943 0.091	0.986 0.109	1.028 0.129	1.110 0.176	1.188 0.233	1.225 0.265	1.335 0.377	1.439 0.515	1.473 0.567	1.539 0.680	1.603 0.806	1.635 0.874
Coefficient for part-full pipes:												
	90	100	110	120	130	140	150	200	200	200	200	200

$k_s = 1.500\text{mm}$ $i < 0.004$

END OF DATA